

CERTIFICATE OF COMPLIANCE

Certificate Number 20191118-S36217
Report Reference S36217-20190528
Issue Date 2019-NOVEMBER-18

Issued to: HONEYWELL INTERNATIONAL (I) PVT LTD
Honeywell Life Safety Division
SECTOR 36
PACE CITY II
Gurgaon, 122004 INDIA

**This certificate confirms that
representative samples of**

Heat-automatic Fire Detectors
Fire Alarm Subassembly - Electronic fixed temperature heat
detector, Models HM-FHSE-UL, HM-HTSE-UL. Electronic
rate-of rise with fixed temperature heat detector, Model
HM-RHSE-UL.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: Standard for Safety for Heat Detectors for Fire Protective
Signaling, ANSI/UL 521.

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

