

UQGS.S35766 Heat-automatic Fire Detectors

Page Bottom

Heat-automatic Fire Detectors

See General Information for Heat-automatic Fire Detectors

RAVEL ELECTRONICS LTD S35766

UNIT 11

CHANCEL INDUSTRIAL ESTATE

NEWHALL STREET

WILLENHALL, UNITED KINGDOM WV13 1NX UNITED KINGDOM

| | | | | | Spacing (Ft) | |
|--|---------|-------------------------------|------------------------|--------------------|-------------------|-------------------------|
| Model No. | Туре | Compatibility Restrictions | Contact Arrangement | Temp Range (°F) | Smooth Ceiling | to Wall or Partition |
| RE316H-2, ZE316H-2, RE316H-2M, ZE316H-2M, RE316H-2L, ZE316H-2L, RE316H-2LM, ZE316H-2LM | | | | | | |
| | FT, ROR | D2 | - | 144 | 50 | 25 |
| | | | | 20 | 50 | 25 |
| RE316H-4, ZE316H-4, RE316H-4M, ZE316H-4M | | | | | | |
| | FT, ROR | None | - | 144 | 50 | 25 |
| | | | | 20 | 50 | 25 |
| RE317A-H, ZE317A-H, RE317A-HL, ZE317A-HL | | | | | | |
| | FT, ROR | D2 | - | 144 | 50 | 25 |
| | | | | 20 | 50 | 25 |
| RE317D-H, ZE317D-H, RE317D-HL, ZE317D-HL | | | | | | |
| | FT, ROR | D2 | - | 144 | 50 | 25 |
| | | | | 20 | 50 | 25 |

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

FT - Fixed temperature

ROR - Rate of rise

Last Updated on 2016-03-17

Questions? Print this page Terms of Use Page Top

© 2016 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2016 UL LLC".