



**UL Product iQ**  
 UL'S NEXT GENERATION CERTIFICATIONS SEARCH  
 The same trusted data in a modern search engine.

**NOW AVAILABLE**

**▶ LEARN MORE**

## UQGS.S911 Heat-automatic Fire Detectors

[Page Bottom](#)

### Heat-automatic Fire Detectors

[See General Information for Heat-automatic Fire Detectors](#)

#### SYSTEM SENSOR UNINCORPORATED, DIV OF HONEYWELL INTERNATIONAL INC

S911

3825 Ohio Ave  
 Saint Charles, IL 60174-5467 USA

**Trim Ring**, Model(s) TR300, followed by a two-digit suffix, indicating color: no suffix for white, -IV for ivory, -BL for black, etc.

**Color Kit**, Model(s) CK300, followed by a two-digit suffix, indicating color: no suffix for white, -IV for ivory, -BL for black, etc.

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
<b>2251T, 2251TM, 2251TB, 2251TMB, 2251TMBC (a)</b>						
	FT/ROR	D2	-	135	50	25
<b>2351TB, 2351TBA</b>	FT	D1	-	-	-	-
<b>TC806B1043, TC806B1068, TC840M1005, TC840M1013, TC806B1084, TC840M1021 (a)</b>						
	FT/ROR	D2	-	135	50	25
Base Model	Related Detector			Control Unit Compatibility Restrictions		
<b>B210W, B501W</b>	FWD-200ACCLIMATE, FWH-200FIX135, FWH-200ROR135			B2		

B2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

D1 - Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

FT/ROR - Fixed temperature/rate of rise combination

FT - Fixed temperature

(a) - For connection to Fike model Cybercat control panel.

[Last Updated](#) on 2017-12-26

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

6/7/2018

UQGS.S911 - Heat-automatic Fire Detectors

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".